

# **The Corporation of the Municipality of Port Hope**



## **Port Hope Drinking Water System**

**DWS # 260058006**

**2015 Annual Report**



**OPTIONAL ANNUAL REPORT TEMPLATE**

<b>Drinking-Water System Number:</b>	260058006
<b>Drinking-Water System Name:</b>	Port Hope Drinking Water System
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of Port Hope
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2015 – December 31, 2015

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [<input checked="" type="checkbox"/>] No [ <input type="checkbox"/> ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [<input checked="" type="checkbox"/>] No [ <input type="checkbox"/> ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Municipal Development Team Office, Municipal Libraries, Municipal Administrative Office, Water Treatment Plant.</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ <input type="checkbox"/> ] No [ <input type="checkbox"/> ]</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ <input type="checkbox"/> ] No [ <input type="checkbox"/> ]</p>
---	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
Yes [  ] No [  ]



Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method \_\_\_\_\_

### Describe your Drinking-Water System

#### System Information

Port Hope Drinking Water System is classified as Large Municipal Residential system and consists of the Water Treatment Plant (WTP) and Distribution System. The WTP provides ultrafiltration water treatment for the water system. The WTP is located at 35 Marsh St in the Municipality of Port Hope, County of Northumberland, Ontario. The Municipality is the Owner and Operator of the Port Hope Drinking Water System that serves the community of Port Hope with a population of 12,500.

#### Drinking Water Quality Management System

Port Hope Drinking Water System is operated in accordance with the Municipal Drinking Water License # 146-101, the Drinking Water Works Permit # 146-201 and the Municipality's Drinking Water Quality Management System Operational Plan # 146-401.

The following describes the components of the Port Hope Drinking Water System:

#### Raw Water Source

The water supply for Port Hope WTP is obtained from Lake Ontario. Lake Ontario water is of good quality and can be described as a large body of clear-coloured water of low turbidity. The Lake water's temperature ranges from 0°C (winter) to approximately 22°C (summer). The raw water source is classified as surface water, which means that it is considered to be an unprotected source. Raw water requires full treatment at Port Hope's Water Treatment Plant to make it drinkable or potable.

#### Intake Structure

Raw water is taken into a 750-mm diameter intake pipe through the intake structure. The existing intake structure and 750 mm intake piping was retrofitted to include a 900 mm on shore addition. This intake is utilized to draw water from Lake Ontario to the low lift pumping station. The low lift pumping station is where water undergoes coarse screening.

#### Raw Water pumping

The raw water pumping station consists of several raw water chambers, one (1) raw water travelling screen, two (2) manually cleaned screens (i.e., for standby purposes), and three (3) low lift pumps (with provision for a fourth). During the Zebra Mussel



season the raw water is dosed with chlorine for Zebra Mussel control prior to ultrafiltration process.

The raw water quality is monitored by Operations staff at the Water Treatment Plant.

#### Water Treatment

Raw water is treated by passing through the ultrafiltration system. The ultrafiltration process removes organics and solids as well as safeguards against *giardia* and *cryptosporidium* contamination. The water treatment facilities consist of a Zenon ZeeWeed 1000 membrane ultrafiltration system which includes four (4) membrane tanks (each tank contains two (2) filtration cassettes with a total capacity for four cassettes) and associated cleaning and backwashing equipment. Following ultrafiltration, filtered water is disinfected by using a chlorine gas system (primary disinfection). The post-chlorination (secondary chlorination) is used as required to maintain a fixed chlorine residual levels in the water leaving the plant. Following the disinfection process, the water is ready for consumption by consumers within the distribution system. Five (5) high lift pumps (with provision for a sixth) lift treated water to the distribution system. The Water Treatment Plant has a rated capacity of 20,000 M<sup>3</sup>/d. It is expected that this capacity will provide potable water to the Municipality of Port Hope for a period greater than the 20 year planning period.

#### Water Storage Facilities

At the WTP, potable water storage consists of twined reservoirs that have a total rated capacity of 5000 M<sup>3</sup>. Off site storage facilities in Zone 1 include a Standpipe that can hold up to 1,205 M<sup>3</sup>. Zone 2 has an underground reservoir that can hold up to 2273 M<sup>3</sup> and an elevated tank that can hold up to 3000 M<sup>3</sup>.

#### Process Wastewater System

The WTP provides process residue management consisting of equalization storage and solids separation. Two (2) equalization tanks precede two (2) parallel tube settling units. Settled solids at the base of each wastewater clarifier are pumped via a sewage pumping station (located outside the WTP) to the sanitary sewer, while wastewater supernatant is analysed and dechlorinated prior to a discharge to Lake Ontario.

#### Water Distribution System

Due to Port Hope's hilly terrain, the community has been divided into two pressure zones. Zone 1 is located in the lower parts of the community while Zone 2 controls the higher area. A booster pumping station, an elevated tank and an in-ground reservoir/pumping station are located in Zone 2 to maintain adequate pressures and flows in Zone 2. Zone 1 pressures are maintained via the Pumping Station at the Water Treatment Plant and the Standpipe located at the highest point of Zone 1.

#### Supervisory Control and Data Acquisition (SCADA)

SCADA system consists of numerous computer systems that control and monitor the drinking water system and the water quality at all times. Operational staff monitors and control these systems to insure their proper operation and water quality. All



**Operational Staff for Port Hope Drinking Water System are fully certified by the Ministry of the Environment & Climate Change.**

**List all water treatment chemicals used over this reporting period**

Chlorine Gas

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

**Budgeted equipment repairs and general maintenance for WTP in 2015 totaled \$187,933. Capital projects expenses for WTP in 2015 totaled \$14,177. Budgeted linear infrastructure maintenance in Distribution system totaled \$35,000; some unexpected expenditures related to watermains maintenance totaled \$47,023.**

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
August 20, 2015	Total coliform	1	CFU/100 mL	Re-sample and test	August 26, 2015

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03 during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
<b>Raw</b>	53	0-23	0-5600	N/A	N/A
<b>Treated</b>	53	0	0	53	0- >2000
<b>Distribution</b>	372	0	0-1	372	0-15

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab	Range of Results (min #)-(max #)	Unit of Measure

*NOTE: For continuous monitors use 8760 as the number of samples.*



	<b>Samples</b>		
<b>Raw Turbidity</b>	8760	0.00 - 99.99	NTU
<b>Treated Turbidity</b>	8760	0.00 – 2.00	NTU
<b>Primary Chlorine</b>	8760	0.00 – 2.02	mg/L
<b>Secondary Chlorine</b>	8760	0.00 – 2.38	mg/L
<b>Distribution Chlorine (Grab Samples)</b>	1,634	0.22 – 2.07	mg/L
<b>Distribution Chlorine (Reservoir)</b>	8760	0.00 – 4.96	mg/L
<b>Distribution Chlorine (Elevated Tank)</b>	8760	0.00 – 3.62	mg/L
<b>Fluoride (If the DWS provides fluoridation)</b>	N/A	N/A	N/A

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

<b>Date of legal instrument issued</b>	<b>Parameter</b>	<b>Date Sampled</b>	<b>Result</b>	<b>Unit of Measure</b>
Nov.24, 2015 Municipal Drinking Water License 146-101	Process waste water, Total Chlorine Residual	Continuously	0.00 – 2.00	mg/L
Nov.24, 2015, Municipal Drinking Water License 146-101	Process waste water, Total suspended solids	Monthly	15.00 Annual Average	mg/L

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

<b>Parameter</b>	<b>Sample Date</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>Exceedance</b>
<b>Antimony</b>	Aug. 5/15	0.14	ug/L	No
<b>Arsenic</b>	Aug. 5/15	0.9	ug/L	No
<b>Barium</b>	Aug. 5/15	21.9	ug/L	No
<b>Boron</b>	Aug. 5/15	24.8	ug/L	No
<b>Cadmium</b>	Aug. 5/15	0.003 <MDL	ug/L	No
<b>Chromium</b>	Aug. 5/15	0.12	ug/L	No
<b>*Lead</b>	N/A			
<b>Mercury</b>	Aug. 5/15	0.01 <MDL	ug/L	No
<b>Selenium</b>	Aug. 5/15	0.16	ug/L	No
<b>Sodium</b>	Aug. 5/15	15.7	mg/L	No
<b>Uranium</b>	Aug. 5/15	0.382	ug/L	No
<b>Fluoride</b>	Aug. 5/15	0.11	mg/L	No
<b>Nitrite</b>	Dec. 1/15	0.003 <MDL	mg/L	No
<b>Nitrate</b>	Dec. 1/15	0.374	mg/L	No



\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
<b>Plumbing</b>	<b>N/A</b>			
<b>Distribution</b>	<b>8</b>	<b>0.01 &lt;MDL – 0.85</b>	<b>ug/L</b>	<b>0</b>

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Aug. 5/15	0.02 <MDL	ug/L	No
Aldicarb	Aug. 5/15	0.01 <MDL	ug/L	No
Aldrin + Dieldrin	Aug. 5/15	0.01 <MDL	ug/L	No
Atrazine + N-dealkylated metabolites	Aug. 5/15	0.08	ug/L	No
Azinphos-methyl	Aug. 5/15	0.05 <MDL	ug/L	No
Bendiocarb	Aug. 5/15	0.01 <MDL	ug/L	No
Benzene	Aug. 5/15	0.32 <MDL	ug/L	No
Benzo(a)pyrene	Aug. 5/15	0.004 <MDL	ug/L	No
Bromoxynil	Aug. 5/15	0.33 <MDL	ug/L	No
Carbaryl	Aug. 5/15	0.05 <MDL	ug/L	No
Carbofuran	Aug. 5/15	0.01 <MDL	ug/L	No
Carbon Tetrachloride	Aug. 5/15	0.16 <MDL	ug/L	No
Chlordane (Total)	Aug. 5/15	0.01 <MDL	ug/L	No
Chlorpyrifos	Aug. 5/15	0.02 <MDL	ug/L	No
Cyanazine	Aug. 5/15	0.03 <MDL	ug/L	No
Diazinon	Aug. 5/15	0.02 <MDL	ug/L	No
Dicamba	Aug. 5/15	0.20 <MDL	ug/L	No
1,2-Dichlorobenzene	Aug. 5/15	0.41 <MDL	ug/L	No
1,4-Dichlorobenzene	Aug. 5/15	0.36 <MDL	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Aug. 5/15	0.01 <MDL	ug/L	No
1,2-Dichloroethane	Aug. 5/15	0.35 <MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Aug. 5/15	0.33 <MDL	ug/L	No
Dichloromethane	Aug. 5/15	0.35 <MDL	ug/L	No
2-4 Dichlorophenol	Aug. 5/15	0.15 <MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Aug. 5/15	0.19 <MDL	ug/L	No
Diclofop-methyl	Aug. 5/15	0.40 <MDL	ug/L	No
Dimethoate	Aug. 5/15	0.03 <MDL	ug/L	No
Dinoseb	Aug. 5/15	0.36 <MDL	ug/L	No
Diquat	Aug. 5/15	1 <MDL	ug/L	No
Diuron	Aug. 5/15	0.03 <MDL	ug/L	No
Glyphosate	Aug. 5/15	1 <MDL	ug/L	No
Heptachlor + Heptachlor Epoxide	Aug. 5/15	0.01 <MDL	ug/L	No
Lindane (Total)	Aug. 5/15	0.01 <MDL	ug/L	No



Malathion	Aug. 5/15	0.02 <MDL	ug/L	No
Methoxychlor	Aug. 5/15	0.01 <MDL	ug/L	No
Metolachlor	Aug. 5/15	0.01 <MDL	ug/L	No
Metribuzin	Aug. 5/15	0.02 <MDL	ug/L	No
Monochlorobenzene	Aug. 5/15	0.3 <MDL	ug/L	No
Paraquat	Aug. 5/15	1 <MDL	ug/L	No
Parathion	Aug. 5/15	0.02 <MDL	ug/L	No
Pentachlorophenol	Aug. 5/15	0.15 <MDL	ug/L	No
Phorate	Aug. 5/15	0.01 <MDL	ug/L	No
Picloram	Aug. 5/15	1 <MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	Aug. 5/15	0.04 <MDL	ug/L	No
Prometryne	Aug. 5/15	0.03 <MDL	ug/L	No
Simazine	Aug. 5/15	0.01 <MDL	ug/L	No
THM (NOTE: show latest annual average)	<b>2015</b>	43.5	ug/L	No
Temephos	Aug. 5/15	0.01 <MDL	ug/L	No
Terbufos	Aug. 5/15	0.01 <MDL	ug/L	No
Tetrachloroethylene	Aug. 5/15	0.35 <MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	Aug. 5/15	0.20 <MDL	ug/L	No
Triallate	Aug. 5/15	0.01 <MDL	ug/L	No
Trichloroethylene	Aug. 5/15	0.44 <MDL	ug/L	No
2,4,6-Trichlorophenol	Aug. 5/15	0.25 <MDL	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Aug. 5/15	0.22 <MDL	ug/L	No
Trifluralin	Aug. 5/15	0.02 <MDL	ug/L	No
Vinyl Chloride	Aug. 5/15	0.17 <MDL	ug/L	No

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample
N/A			





February 17, 2016

MEMO TO: R. Trumper, Water Operations Manager

MEMO FROM: B. Gilmer, Director of Corporate Services/Clerk

RE: 2015 Annual Report for Port Hope Drinking Water System

Please be advised that the above noted Staff Report dated February 9, 2016 was duly presented at the Committee of the Whole meeting held on February 16, 2016 and was subsequently received for information purposes.

I provide this for your information files.

Yours truly,

Original signed by:

B. Gilmer,  
Director of Corporate Services/Clerk

cc: Councillor T. Hickey  
P. Angelo, Director of Works and Engineering  
file copy